

This information is supplied for reference only. Read and follow the Installation Instructions supplied with the venting components and accessories.

The weights listed below may be used to estimate the installed weight of a venting system in order to determine the suspended load on pre-existing or installer-supplied or field-fabricated structures, hangers, and supports. Weights for elbows, tees, and other fittings may be estimated based on this chart and the corresponding "Technical and Dimensional Data" document.

In accordance with UL1738, a support must be capable of withstanding a static load that is 4 times the weight imposed by the heaviest assembly the support will be required to sustain in service. Installer-supplied or field-fabricated supports should comply with this guideline, but will not be considered "UL Listed". Only supports supplied by Heat-fab and anchored to adequate structural elements as required in our installation and maintenance manuals will be UL Listed for use with a Saf-T Vent system.

Please Note: These weights do not include cartons or other packaging materials – use caution if estimating weights for shipping purposes.

This information is provided for reference only, and is subject to change without notice.

Vent Diameter	Approximate Pounds per Linear Foot				
	SC	EZ Seal	CI Plus	CI	GC
3	1.5	0.5	--	1.5	--
4	2.0	0.7	3.5	2.0	--
5	--	1.0	4.0	3.0	--
6	--	1.1	4.5	3.5	--
7	--	1.3	5.0	4.0	--
8	--	1.5	5.5	4.5	--
9	--	2.0	6.0	5.5	--
10	--	2.3	7.0	6.0	--
12	--	2.5	8.0	7.0	--
14	--	3.0	9.0	8.0	--
16	--	3.5	10.0	9.5	--
18	--	--	12.0	--	5.5
20	--	--	13.5	--	6.0
22	--	--	14.5	--	6.5
24	--	--	16.0	--	7.0
26	--	--	19.5	--	10.0
28	--	--	23.0	--	11.0
30	--	--	24.5	--	12.0
32	--	--	26.0	--	13.0